

**JOHN F. KENNEDY ELEMENTARY  
1310 RATZER ROAD**

Test Date - 6/2/16 & 9/6/16

**KEY:**

**TNR: Testing Not Required  
ND: None Detected      BS: Below DEP/EPA Standard  
DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION**

<b>SAMPLE NUMBER</b>	<b>DESCRIPTION</b>	<b>RESULT</b>	<b>NOTES</b>
L6428036-1	WATER FOUNTAIN RIGHT MEDIA CENTER	0.076	BS
L6428036-2	CLASSROOM 21 SINK	0.121	TNR/BS
L6428036-3	CLASSROOM 15 SINK	0.046	TNR/BS
L6428036-4	BOYS RM 2ND FL SINK 4	0.155	TNR/BS
L6428036-5	GIRLS RM 2ND FL SINK 2	0.035	TNR/BS
L6428036-6	CLASSROOM 18 SINK	0.061	TNR/BS
L6428036-7	CLASSROOM 17 SINK	0.032	TNR/BS
L6428036-8	GIRLS RM 2ND FL SINK 4	0.044	TNR/BS
L6428036-9	CLASSROOM 14 SINK	0.047	TNR/BS
L6428036-10	WATER FOUNTAIN LEFT MEDIA CENTER	0.078	BS
L6428036-11	BATHROOM SINK NEXT BOYS RM 2ND FL	0.0170	TNR/BS
L6428036-12	CLASSROOM 20 SINK	0.046	TNR/BS
L6428036-13	WOMENS ROOM SINK INSIDE GIRLS RM	0.032	TNR/BS
L6428036-14	CLASSROOM 19 SINK	0.050	TNR/BS
L6428036-15	CLASSROOM 16 SINK	0.087	TNR/BS
L6428036-16	BOYS RM 2ND FL SINK 3	0.024	TNR/BS
L6428036-17	CLASSROOM 23 SINK	0.040	TNR/BS
L6428036-18	CLASSROOM 22 SINK	0.010	TNR/BS
L6428036-19	BOYS RM 2ND FL SINK 1	0.029	TNR/BS
L6428036-20	GIRLS RM 2ND FL SINK 3	0.033	TNR/BS
L6428036-21	CLASSROOM 12 SINK	0.097	TNR/BS
L6428036-22	GIRLS ROOM 2ND FL SINK 2	0.041	TNR/BS
L6428036-23	SLOP SINK NEXT TO GIRLS RM 2ND FL	0.011	TNR/BS
L6428036-24	BOYS RM 2ND FL SINK 2	0.030	TNR/BS
L6428036-25	FOUNTAIN NEXT TO GIRLS RM 2ND FL	0.024	BS
L6428036-26	CLASSROOM 13 SINK	0.058	TNR/BS
L6428036-27	CLASSROOM 8 SINK	0.108	TNR/BS
L6428036-28	GIRLS RM BY CUSTODIAN OFFICE SINK RIGHT	0.042	BS
L6428036-29	BOYS RM BY CUSTODIAN OFFICE SINK RIGHT	0.037	BS
L6428036-30	STAFF ROOM SINK	0.021	BS
L6428036-31	BOILER ROOM SINK	0.048	TNR/BS
L6428036-32	CLASSROOM 32 SINK	0.018	TNR/BS
L6428036-33	KITCHEN SINK ON ISLAND	0.008	BS
L6428036-34	WATER FOUNTAIN BY MUSIC ROOM	0.005	BS
L6428036-35	KITCHEN SINK ON WALL MIDDLE	0.023	BS

L6428036-36	CLASSROOM 7 FOUNTAIN	0.017	BS
-------------	----------------------	-------	----

**JOHN F. KENNEDY ELEMENTARY**  
**1310 RATZER ROAD**

Test Date - 6/2/16 & 9/6/16

**KEY:**

**TNR: Testing Not Required**  
**ND: None Detected      BS: Below DEP/EPA Standard**  
**DEP & EPA STANDARD LEAD LEVEL: < 15.000 PARTS PER BILLION**

L6428036-37	KITCHEN SINK ON WALL LEFT	0.057	BS
L6428036-38	MENS RM SINK BY MUSIC ROOM	0.033	TNR/BS
L6428036-39	CLASSROOM 6 SINK	0.046	TNR/BS
L6428036-40	CLASSROOM 1 FOUNTAIN	0.046	BS
L6428036-41	LADIES RM SINK BY MUSIC ROOM	0.022	TNR/BS
L6428036-42	KITCHEN SINK ON WALL RIGHT	0.036	BS
L6428036-43	BOYS RM BY CUSTODIAN OFFICE SINK LEFT	0.024	TNR/BS
L6428036-44	NURSES OFFICE SINK	0.036	BS
L6428036-45	CLASSROOM 3 SINK	0.092	TNR/BS
L6428036-46	CLASSROOM 1 SINK	0.063	TNR/BS
L6428036-47	CLASSROOM 10 FOUNTAIN	0.018	BS
L6428036-48	CLASSROOM 4 FOUNTAIN	0.008	BS
L6428036-49	CLASSROOM 9 SINK	0.031	TNR/BS
L6428036-50	CLASSROOM 4 SINK	0.021	TNR/BS
L6428036-51	CLASSROOM 7 SINK	0.061	TNR/BS
L6428036-52	MUSIC ROOM SINK	0.051	BS
L6428036-53	GIRLS ROOM SINK LEFT BY CUSTODIAN	0.027	TNR/BS
L6428036-54	CLASSROOM 5 SINK	0.090	TNR/BS
L6428036-55	CLASSROOM 11 SINK	0.062	TNR/BS
L6428036-56	UNISEX BATHROOM SINK BY RM 36	0.018	TNR/BS
L6428036-57	CLASSROOM 10 SINK	0.020	TNR/BS
L6428036-58	CLASSROOM 8 FOUNTAIN	0.018	TNR/BS
L6428036-59	MEDIA CENTER OFFICE SINK	0.080	BS